

# fulltext261342020.pdf

*by*

---

FILE	FULLTEXT261342020.PDF (504.54K)	WORD COUNT	13527
TIME SUBMITTED	02-SEP-2020 07:39PM (UTC+0700)	CHARACTER COUNT	79489
SUBMISSION ID	1378177637		

## Review Article

**A Review of Hybrid Power Generation: Modelling-Simulation, Control Strategy and Future Trend Development**Syafaruddin<sup>1\*</sup> and Donald S. Zinger<sup>2</sup><sup>1</sup>Department of Electrical Engineering, Universitas Hasamuddin, Jalan Poros Malino Km. 6, Gowa 92171, Indonesia<sup>2</sup>Department of Electrical Engineering, Northern Illinois University, 1425 W. Lincoln Hwy., DeKalb, Illinois 60115, US

Received 27 April 2020; Accepted 24 June 2020

**Abstract**

Hybrid power generation is one of the most discussed topics in power engineering society nowadays. It is due to the characteristics of participated power sources are different including the variable input parameters and fluctuation of load demand. Therefore, the main challenges in hybrid system are to find the optimal performance, sizing and configuration for the target of minimum operational cost, maximum efficiency and reliability and reduction of carbon gas emission within the pre-determined constrains. This paper attempts to reveal the typical modelling and simulation procedure, control strategy and future trend development of hybrid power generation. The study yields that the utilization of Hybrid Optimization Model for Electric Renewable (HOMER) software dominates the simulation procedure to obtain the optimum technical, socio-economic and environmental performance of hybrid systems. In this respect, there have been ambitious plans to maximize the potential solar energy with other back-up energy sources to supply the electricity energy demand worldwide. In addition, the variety of control strategy has been implemented to take the advantages utilization of hybrid power generation. In the end, the future trend development is mainly focused on the increase the optimal performance of hybrid system based solar thermal power or other thermal engine systems combined with different types of generating systems.

**Keywords:** hybrid power generation, modeling system, software simulation, control strategy, hybrid thermal systems.

**1. Introduction**

Hybrid power generation is defined as the combinational operation between the renewable and non-renewable energy resources or between the renewable and non-conventional energy resources including the utilization of energy storage systems. In this respect, the non-renewable or conventional power generation is characterized with the most well-known typical power generation in practices with the controllable output electric power, such as hydro power, oil and gas-based engine power generation. Meanwhile, the renewable energy resources are sometimes referred to non-conventional power generation types, such as photovoltaic (PV) systems, wind power and so on where their output power are characterized with uncontrollably, variably and high dependency on environmental conditions. Meanwhile, the non-conventional energy resources are termed to thermal systems-based engine generation which not widely known and implemented, such as fuel cell, hydrogen energy and other derivation of solar thermal energy utilization. Because different types of power generation are elaborated together in a single system, the hybrid power generation is remained being attracted to be investigated in order to find the optimal performance within certain challenges and constraints.

The most common practice of hybrid power generation is in a remote area or in an isolated island. In such area, the electrification is the main problem because of the location is far away from the main electricity grid. The utility is reluctant to

extend the transmission lines due to high cost investment while the returned value of investment is relatively low. The solution for the electrification is to supply the area using diesel generator. The diesel machine is considered to be able to provide electricity supply and to shave the load customers which are characterized with slow variations except the load profile changes significantly between day and night times. It means that the electricity is supplied only at night by the diesel machine, while no electricity activity during day time. However, there are problem operations of diesel engine power generation, such as continuity of fuel supply, oil price and carbon gas emission. The fuel supply is sometimes delayed due to transportation and weather problems especially when the location is completely difficult being accessed. The oil cost is another problem where the price tends to increase recently, while the carbon gas emission is the most considerable side effect of burning oil to produce electricity using diesel engine. All it all, the diesel generator has enormous technical and environmental impacts.

The feasibility study of hybrid power generation in isolated community regarding the engineering, environmental and economic aspects under specific conditions is proposed to solve the global financial problems and greenhouse gas emission. The study focuses on the technical and economic feasibility of replacing diesel engine with different combination of hybrid systems [1]. In fact, the diesel generator has significant technical and environmental considerations [2]. Meanwhile, the utilization of various configuration of hybrid power generation by means the inclusion of PV system and wind energy may have important gain on engineering and economic feasibility in order to meet the electricity demand.

\*E-mail address: syafaruddin@unhas.ac.id

ISSN: 1791-2377 © 2020 School of Science, IHU. All rights reserved.

doi:10.25103/jestr.134.26

In this respect, the model development of optimal control performance of hybrid system-based PV and diesel generator might be designed for the minimization of daily cost of electricity [3]. Also, the real-time experimental benchmark for stand-alone hybrid wind and diesel power with battery systems is performed with the main tasks to improve the behavior of overall systems [4].

The hybrid power of solar and wind energy systems is comprehensively discussed from the innovation in advanced technology approach and control strategy for the global perception and pattern utilization [5]. The connection of hybrid generation has important issues on reliability of grid systems. Even though the variability output of wind-solar hybrid systems, the islanding operation is negligible. Therefore, the islanding detection is a vital issue for distributed generation integration [6]. The optimal combination of such hybrid power generation systems is able to meet the annual load and to minimize the total annual cost to the customers [7]. In this respect, the optimal configuration is presented by the feasibility analysis for input policy of renewable implementation. The purpose of the study is to improve the reliability performance and minimizing the energy storage requirement during the low wind speed condition [8]. In comparison through the experimental study, the PV and wind power contribute as the primary and secondary energy supply, respectively to the load energy share [9].

The solution of optimal power management for standalone hybrid power generation is commonly investigated. The method is to clarify the changes and dynamics of the uncertainty condition to the optimal solutions [10]. In remote location, the provision of stand-alone hybrid generation is often more effectively in terms of generation cost than connected to the power grid. When several type of power sources combination exist, the control strategy of power dispatch is highly important for the economic operation and long term utilization of hybrid systems [11]. An example, the stand-alone hybrid power generation based solar energy is used for the electrification of rural area. In this case, the optimal energy production of combined power generation is prompted to eliminate the drawbacks of other types of generation systems [12]. In addition, the implementation of hybrid power systems in isolated island increases the energy security and promotes the economy and environment perception on green power generation [13].

The energy sources in remote area are characterized abundance which mostly from renewable energy with high promising potentials to be used as electricity energy sources. For instance, the sunlight intensity is normally higher than other locations with longer sun duration. The wind speed is feasible to rotate the blade of wind power. The potential of hydro power for mini- and micro-hydro power generation is constantly available through the year. If the technology is provided for these types of energy sources, then the operation may combine with diesel engine to supply electric power to local customers. The electricity from the solar panel is stored in battery systems during the day and being used during the night time. The wind blows almost every time so that the loads may receive electricity not only at night but just during the day. The hydro power may suppress the output of diesel generator significantly in case of water capacity is more enough, while the load capacity is less enough. In this regard, with the availability of renewable power generation in remote location, the diesel engine is only used to peak-shave the load profiles especially when the load growth demand is gradually increased.

The hybrid combination between the hydro power source with other types renewable power generation has given significance of technical consideration. With the PV systems, it might be impossible due to the high capital cost investment of both power generations [14]. However, an approach to allow this hybrid system to be cost-effective is to utilize the water reservoir and battery banks as the storage energy systems to suppress the complementary characteristic of both power generation types. The theoretical concept is to determine the limit of plants performance within the idealized energy availability function. The high capacity of solar energy in grid connection makes the intermittent power and system frequency that leads to the decrease in power quality [15]. The combination of solar energy with hydro power improves the power quality by means taking the benefits of complimentary output characteristics. The proposed method is intended to maximize the net revenue during lifetime operation in order to meet the optimal sizing of PV system capacity.

The smooth operation, clean and energy efficiency of power generation are the challenges to be solved by the combination between conventional and renewable energy source aided by energy storage components. The scheduling model regarding to effective operation strategy of hybrid power generation is developed with the target of optimum fuel utilization, minimum emission within the fulfilment of energy demand [16]. In this respect, the integrated power generation-based energy storage system may improve the overall efficiency and increase the fuel saving ratio [17]. The configuration of hybrid wind-hydrogen and storage energy system may overcome the low supply-demand and discrete wind speed characteristics. In this case, the energy flow diagram and system performance are presented for the proposed strategy to compare the different option of hybrid configuration [18]. However, to some extents the operation of hybrid power generation-based storage energy hydrogen is quite complex [19]. Therefore, it is important to have generic and flexible decision-making model for the hybrid management strategy in order to achieve good performance when connecting different power sources to energy storage systems.

The proposed hybrid system may also eliminate the battery utilization and environmentally adaptive under partial load operation and could be the best operation strategy when the economic and environmental aspects are fairly considered. For instance, the PV home system is normally installed in remote area with difficult access to the grid connection. However, significant number of this system is not properly function or not working at all due to substandard equipment, lack of user awareness, inability to maintain their systems, as well as the nonexistence of after sales services. Consequently, it impacts to the battery disposal which is danger potentials to the environment. Implementation of hybrid systems of PV-wind power may reduce significantly the battery disposal without effecting the load demand [20].

The hybrid power system contributes for the significant generating capacity. The share information and experience are to increase the capacity between renewable energy, to improve the hybrid concept of renewable energy/energy storage device and to utilize the micro grid systems with variety connection of power sources [21]. In this case, the strategy of hybrid energy system-based PV, micro-gas turbine and tri-generation (power-heating-cooling) system is presented to obtain the economic and environmental performance by means the life cost analysis and actual emission, respectively [22]. Another name of hybrid power generation is the poly-generation when the energy utilization from different power sources end up in the customers' side in the form of electricity, heating-

cooling and desalination [23]. The generating systems is capable to overcome the output fluctuation of renewable energy sources, to reduce the cost of generation and to mitigate the carbon gas emission. Also, the energy balance analysis utilized for preferred energy unit of PV-bio hybrid power unit to realize the self-sustaining high-strength wastewater treatment application [24]. In this respect, optimal performance of hybrid power generation based reverse osmosis desalination system is modeled and simulated for the minimum operational cost [25]. Also, the performance of hybrid power generation based hydro power and wind energy system is analyzed for energy demand in water treatment plants including the economic analysis of payback period [26].

Variety of power sources combination is approached to take the advantages of hybrid power generation and to obtain the optimal performance criteria. The hybrid renewable based marine and land source availability is investigated and compared for the cost payback and profitability. The optimal land and ship location are the significant factors to decrease the fuel consumption and greenhouse gas emission [27]. In this case, the transportation and installation planning for offshore energy platform is investigated and evaluated for floating hybrid power generation including the expected optimal performance. Also, the optimum sizing-based energy production of stand-alone hybrid power generation systems for marine context application is investigated according to the minimization of overall system costs and carbon emission [29]. An example, the utilization of hybrid power system in ship has attracted more attention, especially the use of solar combined with storage energy devices. In this respect, it is essential to have the optimal size of hybrid system within the minimum investment cost and carbon gas reduction [30]. Also, it is important to determine the optimal size of energy storage systems in hybrid system of ship application for the target reductions of fuel cost, investment cost of energy storage equipment, carbon gas emission [31].

The hybrid performance between PV system and fuel cell technology is getting mature and receives significant attention. For instance, the model of hybrid optimization-based PV system and fuel cell for household application is investigated [32]. The target for this optimization is the minimum annual operation cost and carbon gas emission within the reliable operation of hybrid systems. Completed analysis of economic evaluation, natural gas prices, the optimal electric and thermal balances are accounted for the environmental benefits of hybrid power systems based operating scenarios of PV, fuel cell and battery systems [33]. In this case, the hybrid power management strategy including the daily load profile, solar intensity, operation of battery systems and external energy constraints is considering to solve the economic power dispatch problems. Also, the fully automatic performance of hybrid power generation is highly important. Therefore, it is important to determine the optimal size and operation including the overview of technical-economic configuration [34]. In addition, the hybrid stand-alone application is expected to maximize the hybrid power efficiency through the solution of constraints of optimization problems including the increase the heat and power production, and controlling the carbon emission [35].

Recently, the hybrid power generation based solar thermal power system has been attracted to increase the share of solar energy capacity in electricity demand supply. The review of hybrid power generation based concentrated solar thermal with renewable and non-renewable energy sources has been presented. The common perspectives are the reduction of carbon emission, plant characteristics and performance

metrics. However, some parameters such as energy efficiency, solar-to-electricity efficiency, capacity factor and cost effectiveness need improvement for the competitive hybrid systems [36]. Therefore, it is important to have integrated analysis in finding the key knowledge regarding the attributes, location, area and shape of renewable energy sources potentials to determine the energy production of hybrid systems [37]. In other perspectives, the research investigates the economic, environmental, and technological feasibility of hybrid systems of grid-connected power systems through the improve energy infrastructure, reliable energy supply and implementation of energy policy [38]. With sensitivity analysis, the grid connected hybrid power systems depends on the input parameters of sunlight intensity, load demand and electricity shortage with considering the present cost of equipment [39].

It has been shown that there were incredible efforts to maximize the potentials utilization of hybrid power generation supplying electricity load either in the stand-alone or grid-connected systems. The targets of these efforts are to find the optimal performance, increasing the power generation capacity with low-cost, to obtain the optimal configuration and sizing of participated hybrid system within specified technical constraints and to take the benefits of socio-economic and environmental aspect from the impacts of hybrid power system utilization. These efforts might be supported from different methods of optimization, modeling and simulation including the control strategy for the best-technical and economic system performances. All these summary points are in presented in the following section and finalized with the future trend of hybrid power generation based different solar energy utilizations.

## 2. Modelling and Simulation Techniques

The energy demand and climate environmental concerns have driven the potential energy sources forming the hybrid systems. The serious investigating of the all promising renewable energy source yield the mature technology together with economic and environmental advantages. To achieve these goals, the modelling of hybrid system is highly important. For these reasons, the performance of analysis modelling and control design are addressed to reach the optimum output energy [40]. In this case, the performance of battery systems in stand-alone hybrid power generation is simulated taking into account mathematical model of current rate, the charging efficiency, the self-discharge rate, as well as the battery capacity parameters to fulfil the criteria of both complexity and precision of battery model in highly varied operation conditions [41]. In comparison, the mathematical model of solar thermoelectric and PV hybrid systems is solved with Matlab/Simulink software including the design of logic control for the reliable and effective operation of hybrid systems [42].

Modelling in hybrid power generation is highly important to further investigate the behaviour system performance. The hybrid system based renewable energy and coal-fired generation system is presented to for energy conservation and gas emission reduction. The general matrix model of heat energy balance and energy losses is designed including the investigation of thermo-economic performance, energy conservation and emission reduction potentials [43]. In comparison, the three-dimensional numerical model by finite volume method of hybrid systems of PV and thermoelectric generator (TEG) presented with defined functions is generated to consider the

behaviour of systems [44]. The TEG is installed at the back-side of PV module in order to produce much power than single PV generation systems and to avoid unexpected cooling systems performance due to the existence of TEG. In this respect, the implementation of thermal management is necessary where large temperature difference can be achieved in TEG by the control of heat flow by putting copper plate as thermal concentrator and conductor at both sides [45].

The hybrid power generation is getting popular as the alternative energy supply in rural area as the future of renewable energy utilization and the willingness to reduce fossil fuel consumption. The study provides the model, design and analysis of hybrid systems considering the improving performance, establishing techniques for accurately predicting output and reliably integrating of renewable energy sources with other conventional generating sources [46]. The design method of hybrid power system is presented based modified electric system cascade analysis taking the power pinch analysis as the guideline development of stand-alone hybrid system [47]. The optimal design based minimum loss of power supply probability and number of storage units is achieved through Matlab/Simulink simulation model and the model performance is compared with HOMER simulation output. In addition, the pinch analysis by means the power pinch analysis is used as the graphical method to find the minimum target of outsourced electricity from hybrid energy systems and to determine the amount of excess energy for storage during start-up and normal operation [48]. This method can be used for decision making and design of hybrid systems.

The renewable hybrid generation system-based wind and solar energy is reviewed from the characteristics of abundance and environmentally friendly. In this respect, the hybrid combination is potentials to solve energy shortage problems and fluctuate price. The renewable energy is continuously developed by improving their performance, establishing techniques for accurately predicting their output and reliably integrating them with other conventional generating sources [49]. When solar and wind power are operated independently, they are naturally unstable and totally unreliable. However, the aggregation of both resources could increase the output energy and reduce the power fluctuation. The hybrid power-based wind and solar energy for rooftop installation of residential location is simulated with Digsilent software in terms of voltage profile, voltage imbalance, transformer loading, and curtail dump power of PV-wind power hybrid systems which consider the meteorological data and load demand [50].

Meanwhile, the high accurate static and dynamic model of fuel cell is presented to show the capability of fuel cell to follow the variation of load demand fast. In this case, the hybrid combination of fuel cell with battery system in order to achieve fast energy compensation to follow the dynamic changes of load with also considering to eliminate the destructive harmonics effect [51]. The optimization and simulation of energy conversion process on stand-alone hybrid power generation-based PV system, fuel cell and battery are performed under Aspen Plus environment software [52]. In this case, the dispatching problem and operational feasibility are solved under different scenario analysis. In other cases, similar software is used to evaluate the performance of near zero carbon emission of hybrid power generation in terms of efficiency energy conversion and balanced integration of each power generation components [53].

All in all, the Matlab software is commonly used to solve mathematical model in hybrid power generation. The steady-state mathematical model is utilized to simulate different operating condition of fuel cells, such as fuel utilization factor and average current density for the target of electrical and total system efficiency [54]. The information is beneficial as the prior knowledge for the optimal design and optimization of hybrid systems. In this case, the total energy of hybrid systems-based fuel cell and exhaust gas from chiller is presented to provide power, heating and cooling concurrently. Also, numerical simulation of transient performance of hybrid system based concentrating solar thermal and thermoelectric generator is presented under the Matlab Simulink software simulator [44]. The aim of this study is to provide thermal mechanism to increase the efficiency and performance of the hybrid module. In addition, the optimization of the potentials of local energy source in the form of hybrid power systems of micro hydro systems and PV panel is analysed with HOMER and Matlab software based on the availability of water resources and load profiles [56]. The simulation results yield with the largest capacity of micro hydro, it reduces the energy cost and carbon gas emission significantly but high investment cost.

Regarding the modelling and simulation techniques in hybrid power generation systems in [40-56], it is highly important to gain beneficial information according to the software and hardware availability, performance evaluation, validity results, novel aspects and significant achievement. These identified reports are comprehensively summarized in Table 1 as follows.

**Table 1.** Modelling and simulation techniques in solving hybrid power generation problems

Hybrid systems	Construction design		Performance evaluation		Validity results		Refs.
	Software	Hardware	Analysis	Simulation	Novelty	Significances	
Wind power, solar panels & balance of systems	None (review article)		Fault analysis & management technique	Modelling of real-time system	Supervisory control system & data acquisition	Effective and efficient energy moderation in the near future	[40]
			Modelling systems	Technical performance, accuracy & reliability	Trend hybrid power systems	Technical feasibility & competitiveness	[46]
			Design, operation and control of PV-wind power	Improve performance, accuracy & reliability	Future potential development	Economic attractiveness and user's acceptance	[49]

	None (modelling approach)	Telecommunication relay station	Current rate, charging efficiency, self-discharge rate & battery capacity	Mathematical approach of lead-acid battery behaviours	Statistical analysis & probability distributions	Battery working states in real hybrid system	[41]
	Matlab/Simulink & HOMER	Real system in Oujda city	Modified electric system cascade	Optimal design algorithm	Power pinch analysis	Promising costs of energy	[47]
	DIgSILENT PowerFactory	LV network with 74 residential homes through 10 mini-pillar connections.	Optimal design under unbalanced three-phase voltage	Voltage profile, voltage imbalance, transformer loading & curtail dump power	Low voltage residential energy utilization	Optimal & suitable combination of PV-wind power capacities	[50]
PV- thermo-electric- systems			73 Sub-systems and energy of hydrogen storage tank	Mathematical model of hybrid systems	Design of logic control systems	Reliable & effective solar hybrid system	[42]
	Matlab software	None (modelling approach)	Heat sink with water-media fluid	Numerical simulation approach	Harvesting heat loss & improved efficiency performance	Transient performance of CPV-TEG	[55]
		None (modelling approach)	Electrical and thermal behaviours	TEG modules & optical concentration ratios	Homogeneous medium & finite volume method- Copper plate concentrator	Concentration ratio with heat sink characteristics	[44]
	ANSYS with finite element method	Thermal concentrated PV-TE systems	Heat flow & temperature distribution	Thermal management		High efficiency in absence of sunlight & economic feasibility	[45]
RE with coal-fired power generation	Matlab software	None (modelling approach)	General matrix models heat balance & exergy losses	Thermo-economic performance, energy conservation & emission reduction potentials	High increments of thermal performance & critical energy conservation potential.	Improved thermo-economic performance indicators with increasing shunt coefficient	[43]
Hybrid RE systems	None (modelling approach)		Power pinch analysis	Optimal networks for recovery and conservation of resources	Management of storage systems	Hybrid power system design	[48]
Fuel cell & battery systems	PROTEUS and MATLAB environments	None (modelling approach)	Dynamic response of fuel cells & cost analysis	Dynamic model of fuel cells	Elimination of harmful harmonics	Fast dynamic response	[51]
PV-fuel cell & battery systems	Aspen Plus environment	None (modelling approach)	Dispatching & operational feasibility	Power dispatch & fuel cell performance	New design & analysis urine-to-hydrogen processor	Battery compensation for energy gap	[52]

Solar hybrid systems		GRAZ integrating solar heat systems	Exergy efficiency & carbon capture	Solar heat conversion & performance parameters	Near zero carbon emission	Complementary utilization of fossil fuel & solar heat	[53]
Hybrid Solid oxide fuel cell	Matlab software	SOFC & absorption chiller	Fuel utilization factor and average current density	Steady-state mathematical model	Electrical & cooling efficiencies	Design & optimization of total energy system	[54]
PV - micro hydro plant (MHP)	Matlab software & HOMER	None (modelling approach)	Energy cost, emission reduction & RE	Different capacity of MHP	Trade-off capital cost & system capacity	Maximum performance of power plant	[56]

In comparison, HOMER software is the most dominating computer software program to solve the optimization problems in hybrid power generation (Table 2). The Hybrid Optimization Model for Electric Renewables (HOMER) software is used as a tool for the technical and economic feasibility of stand-alone hybrid systems such as biogas, PV, Diesel Generator, WT and battery systems. The simulation results indicate significant contribution of the hybrid parts, potential of reducing carbon emission and alternative economic option for electrifying the remote area. In general, the technical and economic feasibility of off-grid hybrid power generation can be investigated for the rural area application with this software tool [57]. The analysis of hybrid power generation for rural application is performed to obtain the optimal energy efficient and the optimal location-based cost-effective configuration. Similarly, the software is used to perform technical and economic feasibility of hybrid system considering net present cost, initial capital cost and cost of energy as economic parameters [58].

The feasibility study of hybrid power generation is investigated according to the minimum cost of energy to supply the load demand. The HOMER software has capacity as a tool to measure the sensitivity analysis regarding the technical and economic system feasibility [59]. Also, it gives benefits to investigate the optimal configuration of hybrid system regarding the effect sensitivity of total net present cost and cost of energy environment [60]. The HOMER simulation tool is utilized to evaluate the technical and economical operation and feasibility of hybrid systems based solar and wind power generation [61]. Global environmental perceptions and increase in electricity energy demand triggered the utilization of hybrid power generation with some portions of renewable energy sources. Similarly, the hybrid power generation based solar panel and wind power for remote area application is carried out according to the net present value and considering the sensitivity variables, such as wind speed, irradiance, solar panel and diesel costs [62].

In other applications, the HOMER software package is used to evaluate the techno-economic performance of off-grid and on-grid hybrid systems of diesel generator, PV, wind and battery systems for large electricity demand. The target of simulation is the optimal configuration based the comparison analysis of technical, economical, and environmental aspects. In addition, the yearly demand growth and government policy is taken into account as the influenced parameters for renewable energy project, carbon tax and electricity price [63]. Similarly, the optimal planning model of hybrid power generation-based PV, diesel generator and battery systems is simulated to meet the real load demand. The discussion of optimal

planning is focused on the technical, economic and environmental aspects of hybrid systems including the fluctuation fuel price and economic prospects of hybrid power [64]. Meanwhile, the hybrid systems-based wind power and biogas engine for the standalone application is investigated with HOMER software. The simulation is focused on the technical and economic analysis, such as the optimal values of levelized cost of electricity, capital cost and net present cost in comparison with the independent operation of diesel generator [20, 5].

The techno-economic feasibility of stand-alone hybrid systems for the target zero emission is presented with HOMER software simulation tool considering incident solar radiation, wind speed, electrical demand profile, and equipment characteristics. The optimal economic results from the simulation is measured with total net present cost and cost of energy considering the inflation rate. The sensitivity analysis is also performed to show the correlation between the economical parameters [66]. For instance, the feasibility of off-grid connection hybrid systems is applied for the hotel energy supply. The optimization tool is taken regarding the economic assessment including the sensitivity analysis of input parameters in hybrid systems to the cost and efficiency system performance [67]. Also, the hybrid systems for the telecommunication load in remote area is investigated with HOMER software for the target of efficient energy utilization of renewable energy sources based on technical and economic analysis [68]. Similarly, the simulation of optimal hybrid power generation in hospital building service for the techno-economic performance is simulated with this software. The optimal targets are total net present cost, levelized cost of energy, renewable fraction, excess energy production and the pollutant gas emission of the system. In addition, the sensitivity analysis is taken for the diesel fuel cost and yearly interest rate for the overall system performance [69].

The hybrid system for rural area electrification is presented to reduce the cost and environmental side effects of diesel generator. The high cost operation could be from fuel transportation and fuel price fluctuation. The role of diesel generator can be replaced from different types of renewable energy. For these reasons, the feasibility study is taken with HOMER software for the optimal net present cost and cost of energy. In this case, the study focuses on the operational strategy and sensitivity analysis of the hybrid system for optimal performance [70]. The hybrid combination between the solar energy and diesel energy has been the prominent option to solve the problem of energy shortage due to the depletion of fossil fuel energy sources and promoting clean energy schemes [71]. The HOMER software is utilized to investigate the level cost of energy in different hybrid configuration with

attention is focused on the unmet load, excess electricity generation, fuel savings and reduction in carbon emissions. In remote application, the design, simulation and analysis of hybrid power based solar or wind with diesel generator is presented for the optimal and feasible energy utilization and reducing total system cost [72].

The technical and economic feasibility of grid-connected hybrid power generation for local area is investigated with variety of renewable energy generation. The optimization technique is carried out with HOMER simulation and sensitivity analysis for the robustness and cost-effectiveness of hybrid micro-grid systems [73]. An example, the hybrid operation is investigated for desalination process and to satisfy the electricity energy demand with considering the techno-economic analysis [74]. Also, the hybrid power system based fixed and sun tracking facilities of PV system and micro wind systems is analysed to obtain the optimum configuration and to improve the power generation potentials. Comparative analysis of different configuration is simulated using HOMER software in order to achieve the improved cost of energy [75]. In other cases, the potentials of hybrid power generation by means the diesel generator, tidal power and PV system including storage devices has been discussed to mitigate the electricity shortages. Similar software is used to analyse the technical and economic aspects for certain output capacity and the

proposed system is compared with other systems of the same capacity [76].

Lastly, analysing and modelling performance of stand-alone hybrid power generation is presented for optimal management, operation and sizing of overall systems using demand response programming. In this case, the management strategy-based demand response and potentials of energy reduction is applied to reduce the imbalance between the generation capability and power consumption behaviour. The HOMER software is used as a tool for optimization program including the GAMS software through CPLEX solver [77]. In this case, the modelling of micro-grid system-based hybrid power generation with biogas and wind/solar energy is presented to mitigate the environmental effects. The method of energy hubs is used for different power source integration to satisfy the different energy production scenarios including the payback cost analysis [78]. Also, the integrating of different power generation in rural area eliminate the concern of oil price fluctuation and the ineffective cost solution for grid connection. The economic feasibility of different energy sources is simulated for the optimal solution of fuel consumption and carbon gas emission including the optimal size configuration [79].

Table 2. Summary HOMER software utilization in hybrid power generations

Hybrid systems	Hardware Design	Performance evaluation		Validity results		Refs.
		Analysis	Simulation	Novelty	Significances	
Stand-alone: biogas, PV, DG, WT & battery systems	Biogas genera (9kW), PV modules (10kW), 2 DGs (10kW each), wind turbine (1kW), 72 batteries (390Ah each) & inverters (15kW)	Technical & economic feasibility	Cost of Energy (COE) & total Net Present Cost (NPC)	Potential reduction in Carbon emission	Economic option of power supply in remote area	[57]
PV, wind power & battery systems	PV (3kW), 2 wind turbines (2.6kW) & 18 batteries with no DG		COE of RE sources	Load demand of a typical residential house & carbon emissions limitation	Carbon emissions reduction in detail for single house	[61]
Standalone: PV, Wind power, DG, biogas engine & battery systems	Wind power (10kW), DG (1kW), battery (1156Ah), converter (1kW), PV (1kW) & biogas engine (1kW)		LCOE & NPC	Biogas engine is better solution than DG as power backup	Lower carbon emission with biogas engine as backup power	[65]
PV, DG, tidal power & battery systems	PV (5kW), tidal-hydropower (8.21kW), battery 20 (1156Ah each) DG-1 (10kW), DG-2 (5kW), inverter (10kW), rectifier (10kW)		Model of possible small hybrid power generation system	Economic viability & technical aspects	Analysis of overall system cost	[76]
Remote area: PV & wind power	None (simulated hybrid systems)	NPV & sensitivity variables	Design and simulation of standalone hybrid power systems	Net present cost of generators	Sensitivity variables & optimization process	[62]

PV, DG, wind power & battery systems	PV (1000kW), DG (800kW), wind power (60kW) & battery (130kWh)	Technical, economic & environmental aspects	COE and RE fractions	Annual load growth & governmental energy policies	Low interest loan to RE projects, carbon tax & grid electricity price	[63]
PV, DG, fuel cell & battery systems	Optimal capacity of different configuration of hybrid systems		Optimal planning of hybrid systems	Replacing battery system with fuel cells	Fuel price fluctuation on the economic competitiveness	[64]
PV & DG	PV (4kWp), DG (10kW) & battery storage of 3 h of autonomy connection	Techno-economic feasibility	COE & operational hours of DG	Effect of battery connection	Un-met load, excess electricity generation, fuel savings & carbon emissions reduction	[71]
PV/wind power with DG & battery systems	PV (15kW), wind turbine (3kW) converter (6kW), DG (2.6kW), ATM (57.8kW) & battery (3000Ah)	Optimal feasible energy utilization & total system cost	Optimal solution for energy supply	Design, simulation and analysis of hybrid system for ATM application	Maximum RE with minimum cost	[72]
PV/wind power, bio-gas & battery systems	PV (no power specification), CHP (8000kW), wind power (3000kW) & battery (3000kW)	Energy production scenarios, economic, sustainability gains & pay-back analysis	Energy Hubs methodology: micro-grid operation	Novel micro-grid structure	Integration of hybrid systems of sugar cane plants	[78]

### 3. Control Strategy

The utilization of conventional control combined with advanced control methods as in Table 3 is still one of the main options of the parameters control strategy in hybrid power generation. The time domain operation of stand-alone hybrid power generation-based wind power, wave energy and compressed air energy storage for remote island service is presented. The simulation results yield that the power-load supply is stable in terms of power and frequency with optimal PI controller [80]. Another approach, the automatic frequency control of hybrid power systems is presented in the corridor of real output power balance systems. The control schemes are the PID and PD controller to keep the zero-frequency deviation and to damp frequency oscillation, respectively [81]. In this study, the sensitivity analysis and control strategy are evaluated to maintain the frequency performance of hybrid systems. Meanwhile, the robust control for hybrid power generation-based fuel cell and supercapacitor is achieved through the control strategy combination between PI and H infinity controls implemented for DC-DC converter [82]. In this research, the optimization method tries to solve Linear Matrix Inequalities regarding parameters of frequency and time performance. In addition, the three-dimensional PID controller is designed and applied for the dynamic control stability of frequency and power variation of wind power in hybrid power generation [83]. The controller parameters are optimized with dragonfly algorithm and compared with the meta-heuristic algorithm for tuning parameters in terms of convergence rate, minimum fitness value and dynamic system performance.

The control of hybrid power generation for household application is presented with the rule-based control strategy considering the optimal system design and sizing and overall energy performance [84]. The rule base strategy is potentials to be deployed for the purpose cost reduction and components

lifetime increase in hybrid systems. In accordance, the nearly zero energy for building is investigated in terms of design and control regarding the energy saving, indoor thermal comfort and accommodative environment and grid connection. Since the problems is complex with parameters and high expected performance, the optimization methods are required to deal with system sensitivity, uncertainty parameters for the optimal system reliability, efficiency and optimal control of hybrid power generation and energy storage systems [85]. For these reasons, it requires the predictive control for smart and fast response control technologies.

Design of economic supervisory predictive control-based Hardware in the Loop framework for management of hybrid power generation has been developed to deal with some optimal criteria, such as environmental aspects, fuel, energy and storage costs for solar panels, gas micro-turbine and storage units [86]. For short time prediction, the system performs better storage energy control and power management. Similar method in terms of ultra-short time prediction is designed based on weighted moving average filtering for real time variability of power compensation. In this case, the smoothing control of hybrid power generation called plan power curve is presented based module scheduling, grid limitation of power fluctuation, maximizing output of wind and solar power, reduced operation energy storage systems [87]. Meanwhile, adaptive control for frequency and voltage of off-grid hybrid wind-diesel system is proposed based on constrained linear model predictive control [88]. Frequency and voltage control performance can be achieved the field voltage and rotational speed of synchronous generator. Meanwhile, the proposed controller response based on the minimum cost function of voltage and rotor speed errors within the given constraints.

The review of inverter utilization in hybrid power generation is presented in terms of topology front-end interface, energy conversion stages, the control circuit regarding the stabilization, tolerance and system ageing [89]. In this case, novel voltage control algorithm is developed for the stand-alone hybrid power systems through the control technique in pulse width modulation inverter [90]. The proposed controller is presented in real time digital simulator and satisfied with the balanced and unbalanced load conditions. Similarly, design and evaluation of control system for hybrid power generation scheme is presented. The real time control is aimed to maximize the energy efficiency and electrical power management of hybrid systems base fuel cell [91].

For the utilization of MPPT control performance in hybrid power system, the universal tracker is evaluated to solve the

problem of individual controller which are explicitly complicates the system implementation, increases cost, and decreases the accuracy of the MPPT process [92]. The proposed controller may extract high output power, no need for the sophisticated sensors, high efficiency performance and fast time convergence. It is due to the independent MPPT controller for hybrid PV system and fuel cell may give the complicated system structure and creates additional cost [93]. The fast convergence and high accuracy control performance is presented for the hybrid PV-fuel cell systems. In other approaches, the unified MPPT control algorithm is proposed for the hybrid wind power and fuel cell [94]. The proposed method is perfect because no need of sensors, high efficiency performance and fast time convergence.

Table 3. Summary of control strategy

Hybrid Systems	Control strategies	Control operation	Control parameters	Refs.
Wind power, wave energy & compressed air energy storage	GWO & PI controller	Stabilization of power & frequency	Frequency deviation, Power of Compressed Air Energy Storage System (CAES) & net power generation	[80]
Wind power DG, fuel-cell & aqua-electrolyzer	PID & PD controller	Zero-frequency deviation & damping frequency oscillation	Real power balance of DG	[81]
Fuel cell & supercapacitor	PI & H infinity controls	Robust control	Multivariable PI control with $H_\infty$ performance; $H_\infty$ full & reduced order controllers	[82]
Wind power-based hybrid power generation	Three-dimensional PID controller & dragonfly algorithm	Dynamic control stability of frequency & power variation	Time-varying step load perturbation & random wind power perturbation	[83]
PV, DG, battery systems & hydrogen fuel cell	Rule-based control strategy (Hardware-In-Loop test)	Cost reduction, components lifetime increase & energy efficiency -vs- correct system sizing	Optimal design, sizing & energy performance	[84]
Hybrid power generation in integrated buildings	Predictive control based nZEB	Design & control of buildings performance -- fast responses to smart grid & advanced smart technologies	Building performance parameters	[85]
Solar panels, gas micro-turbine & storage units	Supervisory predictive control	Management of hybrid renewable energy system	Optimal criterion of environmental condition, fuel, energy delivery & storage costs	[86]
Wind, solar power & energy storage systems (grid connection)	Pre-plan power curve based smoothing control	Reduced maximum powers fluctuation, maximizing wind-solar power utilization & reducing use of battery energy storage system	Real-time power fluctuation	[87]
Off-grid hybrid wind-diesel system	Constrained linear model predictive control	Adaptive control for frequency & voltage	Field voltage & rotational speed of DG	[88]
Stand-alone; wind solar power, battery & fuel cell	Novel voltage control algorithm	Optimal inverter utilization	Line voltage at PCC	[90]
Hybrid systems-based fuel cell	Real time novel control algorithm	Maximum energy efficiency & power management	Common DC bus through intermediary electronic converters	[91]
Hybrid wind power & fuel cell	Universal tracker algorithm	Optimal MPPT control performance	Output voltages and currents of hybrid system components	[92]
	Unified tracker algorithm		Electrical power of wind energy systems	[94]

Wind turbine, electrolyzer & fuel cell	Multi-loop nonlinear predictive control framework	Dynamic modelling & control of fuel cell outputs	Stack temperature & oxygen excess ratio	[95]
Hybrid wind & battery systems	Robust tracking controller	Stabilization control due to the wind & load fluctuation	Power quality-smooth transition of frequency	[97]
Hybrid power based micro generation systems	Homeostatic regulation & supervisory control	Operational aspect of micro-generation	Power supply & demand towards efficient system equilibrium	[98]
Grid-connected PV & battery systems	Optimal control method & model predictive control	Scheduling power flow under minimum generation cost & dispatching real-time power flow under disturbance condition	Electricity cost - number of constraints: power balance, solar output & battery capacity	[99]
Solar-hydrogen power plants	Microcontroller utilization & Labview data	Balancing mechanism: energy output & consumption in real-time	Proper energy source for specific load	[100]

For wind energy-based hybrid power application, the overview of hybrid systems-based wind turbine, electrolyzer and fuel cell is simulated to show the dynamic response of hybrid system for high load demand and fast load change. The dynamic modelling and control are designed based the multi-loop nonlinear predictive control framework for the safe operation and long-life performance [95]. Enhanced control strategy for the grid connected hybrid solar and wind energy under uncertainty parameters might be also obtained by rotor power management scheme from DFIG stator connected grid [96]. In addition, the modelling and controller design called robust tracking controller is important for the hybrid wind and battery systems [97]. The proposed controller is more effective during disturbance condition due to the wind and load fluctuation.

Finally, the review of hybrid power generation beyond the system thinking and cybernetic point of views, the hybrid system can be seen as dynamically complex adaptive systems in rural application. Therefore, the homeostatic regulation and control is very important to maintain the balance between coordinated power supply and demand response management [98]. This approach to the hybrid systems is focused on the technical operation aspect rather than socio-economic, environmental or regulatory aspects. In addition, the solution of optimal demand side management is proposed in hybrid power systems with optimal control method to schedule the power flow under minimum generation cost in one day and model predictive control to dispatch real-time power flow under disturbance condition [99]. An example, the management system for the hybrid control residential solar and hydrogen power system is presented. The controller is developed based on the microcontroller utilization supported by the Labview data acquisition systems [100]. The proposed controller may perform the balancing mechanism between the energy output and consumption in real-time.

#### 4. Future Trends: Thermal Hybrid Power Generation

The efforts to maximize the benefits utilization of solar energy based solar thermal power systems with other types of generation system will be the future trends of hybrid power generation attempts. The optimal design parameters of hybrid systems based solar thermal and other thermal based power generation is investigated for the optimal cost and effective location within the objective function of minimum energy production cost [101]. The improved performance by means the thermodynamic analysis of solar tower power production

during night time is proposed by the hybrid combination with waste to energy systems [102]. New strategy by the hybrid combination of power systems to solve the problems of environmental pollution and oil price increase and fluctuation. The study has reviewed the integrating of different schemes of solar thermal technology and geothermal gas plants [103]. Also, the thermodynamic perspectives are carried out to determine the limit performance of hybrid power generation-based PV cells and methanol thermal decomposition. The results of the study are important to design principle of highly efficient PV thermal and overall understanding of solar energy application [104].

The hybrid power based solar concentrating energy and biomass systems is numerically simulated from the thermodynamic performance and energy efficiency [105]. The promising research outcome is obtained for the efficient utilization of sunlight potentials, biomass resource and carbon gas reduction. The potentials of different solar technologies based solar thermal power plants hybrid with other type of generation systems. The hybrid of different solar thermal power technologies and biomass is investigated in terms of technology climate data variation and economic feasibility [106]. In this case, the increasing temperature of steam from solar thermal systems is performed in biomass boiler in order to improve the thermodynamic performance and exergy capture in the generation process [107]. Such kind approach may lead to the efficient utilization of renewable energy resources and to decrease the greenhouse gas emission. Meanwhile, hybrid of solar thermal based heliostat field collector with the most thermal input requirement is the new approach and viable solution to increase the share energy portion of renewable energy in the electricity grid in the future [108].

Theoretical model of hybrid types with low concentrated PV module and thermoelectric generator is presented to obtain the possible optimal design and system enhancement [109]. Non-equilibrium thermodynamic theory and law of energy conservation are applied for the performance characteristics in terms of efficiency and output power. The basis of performance optimization and analysis hybrid power generation parameters, such as Thomson effect in conjunction with Seebeck, Joule and Fourier heat conduction effects including the temperature difference of thermoelectric generator is simulated with Matlab environment [110]. In other cases, the thermodynamic method is used to investigate the hybrid performance of optimal design of PV-thermoelectric generator in terms of load mismatching, efficiency and output power [111]. The feasibility and performance of hybrid power generation in the form of thermal energy is reviewed in terms of optimal

operation, challenge and efficient enhancement for the future beneficial applications [112].

The review of hybrid system-based variety of solar energy systems with combine heat and power is presented. The study mentions that electrical modelling and analysis are limited, while limited study of economic and exergy system for the solar concentrating energy systems. Beside the technical overview of such hybrid systems, the economic issues are recommended for the further system development [113]. The hybrid combination of solar energy and combined cycle power generation is investigated with thermodynamic hybrid routine and thermal integration-based Brayton cycle [114]. In addition, the multiple sources with thermal hybrid power systems-based Brayton cycle is investigated from the thermodynamic performance including the energy and exergy analysis and the conversion efficiency with sensitivity analysis [115].

The model of hybrid power generation-based wind, electrolyser and fuel cell is presented taking the analysis of energy and exergy analysis based on thermodynamic, electro-chemical and mechanical models [116]. Similarly, the thermodynamic energy and sensitivity analysis are taken to investigate the hybrid performance based catalytic gasification, fuel cell, oxygen transfer membrane and gas turbine considering the overall thermal parameters of systems [117]. An example in hybrid type of solid oxide fuel cell and an internal combustion engine with the target of improving its efficiency and cost effectiveness using the methods of exergetic and exergoeconomic analysis [118]. The exergetic analysis identifies the location, magnitude, and sources of thermodynamic inefficiencies (exergy destructions and exergy losses) in the system; the largest exergy destruction takes place within the internal combustion engine, followed by the heat exchanger, and the solid oxide fuel cell (SOFC) stack. Meanwhile, exergoeconomic analysis: the cost structure of the SOFC-Engine hybrid system and the exergoeconomic factor of each component is quantified.

In conclusion, the comprehensive review of hybrid system based solid oxide fuel cell and gas turbine is investigated in terms of numerical simulations, experimental analyses, and thermo-economic optimizations. The detailed analysis includes the control strategy for the load following characteristics, best performance of nominal capacity and efficiency reduction during the load fluctuation [119]. Meanwhile, the thermo-economic modelling of different configuration of hybrid systems based solid oxide fuel cell and gas turbine is presented to determine the high efficiency system performance, cost-effective operation and economic revenue of model [120]. The performance evaluation of hybrid system based

solid oxide fuel cell and micro gas turbine is presented consider the comprehensive energy balance and power generation efficiency [121].

## 5. Final Remarks

Regarding the future development of hybrid power generation, the performance of different types of hybrid power generation based thermal configuration is proposed based on thermodynamic analysis [122]. The performance hybrid geothermal and fossil fuel based thermal generation systems is investigated in terms of thermodynamic performance [123]. Similarly, the thermodynamic assessment-based Rankine cycle is proposed for the hybrid systems based solar energy with thermal collector and thermal liquefied natural gas-based power generation. The system optimization includes equivalent efficiency and some existing indices like thermal, cold energy, and exergetic efficiency [124]. Also, the combination between gasified biomass and solar energy based concentrated solar thermal has been investigated in terms of thermodynamic Rankine cycle performance [125]. The increase in concentrated solar thermal process may have positive impacts on hybrid system efficiency and the availability of heat exchanger system will increase the synergy both energy systems. Similarly, the efficiency performance systems are evaluated in hybrid power based gasified biomass and concentrated solar thermal systems [126]. However, there will be complement behaviour of hybrid systems based solar energy and biomass is investigated in terms of thermodynamic performance with Rankine cycle and economic model that covers energy, exergy, economic and environmental perspectives [127]. Based on these facts, there have been ambitious plans to maximize the potential solar energy with other back-up energy sources to supply the electricity energy demand worldwide.

## Acknowledgement

This research is granted by the National Ministry of Research, Technology and Higher Education of Indonesia under Program of Scheme for Academic and Mobility Exchange (SAME) 2018.

This is an Open Access article distributed under the terms of the Creative Commons Attribution License



## References

- Mir-Akbar Hessami, Hugh Campbell, Christopher Sanguinetti, A feasibility study of hybrid wind power systems for remote communities, *Energy Policy*, vol. 39, Issue 2, pp. 877-886, February 2011
- Saïd Bentouba, Mahmoud Bourouis, Feasibility study of a wind-photovoltaic hybrid power generation system for a remote area in the extreme south of Algeria, *Applied Thermal Engineering*, vol. 133, pp. 713-719, 25 April 2016
- Kanzumba Kusakana, Hybrid DG-PV with groundwater pumped hydro storage for sustainable energy supply in arid areas, *Journal of Energy Storage*, vol. 18, pp. 84-89, August 2018
- Djohra Saheb Koussa, M.Koussa, A.Rennane, S.Hadji, A.Boufer-tella, A.Balehouane, S.Bellarbi, Hybrid diesel-wind system with battery storage operating in standalone mode: Control and energy management-Experimental investigation, *Energy*, vol. 130, pp. 38-47, 1 July 2017
- M.S.Hossain, A.K.Pandey, M.A.Tunio, J.Selvaraj, N.A.Rahim, Chapter Ten - The Hybrid Solar Power/Wind System for Energy Production, Observation, Application, and Simulation, *Clean Energy for Sustainable Development*, pp. 337-368, 2017
- Gökay Bayrak, Ersan Kabalci, 'Implementation of a new remote islanding detection method for wind-solar hybrid power plants', *Renewable and Sustainable Energy Reviews*, vol. 58, pp 1-15, May 2016
- W.Kellogg, M.H.Nehrir, G.Venkataramanan, V.Gerez, Optimal unit sizing for a hybrid wind/photovoltaic generating system, *Electric Power Systems Research*, vol. 39, Issue 1, pp. 35-38, October 1996

- [8] Sunanda Sinha, S.S.Chandel, Improving the reliability of photovoltaic-based hybrid power system with battery storage in low wind locations, *Sustainable Energy Technologies and Assessments*, vol. 19, pp. 146-159, February 2017
- [9] R.Maouedj, A.Mammeri, M.D.Draou, B.Benyoucef, Performance Evaluation of Hybrid Photovoltaic-wind Power Systems, *Energy Procedia*, vol. 50, pp. 797-807, 2014
- [10] Ilse Cervantes, Marco Hernandez-Nochebuena, Ulises Cano-Castillo, Ismael Araujo-Vargas, A graphical approach to optimal power management for uncertain OFF-Grid PV-FC-electrolyzer-battery hybrid systems, *International Journal of Hydrogen Energy*, In Press, Corrected Proof, Available online 24 September 2018
- [11] C.Dennis Barley, C.Byron Winn, Optimal dispatch strategy in remote hybrid power systems, *Solar Energy*, vol. 58, Issues 4-6, pp. 165-179, October-December 1996
- [12] R.K.Akikur, R.Saidur, H.W.Ping, K.R.Ullah, Comparative study of stand-alone and hybrid solar energy systems suitable for off-grid rural electrification: A review, *Renewable and Sustainable Energy Reviews*, vol. 27, pp. 738-752, November 2013
- [13] Priyantha Wijayatunga, Len George, Antonio Lopez, Jose A.Aguado, Integrating Clean Energy in Small Island Power Systems: Maldives Experience, *Energy Procedia*, vol. 103, pp. 274-279, December 2016
- [14] Alexandre Beluco, Paulo Kroeff de Souza, Arno Krenzinger, A method to evaluate the effect of complementarity in time between hydro and solar energy on the performance of hybrid hydro PV generating plants, *Renewable Energy*, vol. 45, pp. 24-30, September 2012
- [15] Wei Fang, Qiang Huang, Shengzhi Huang, Jie Yang, Erhao Meng, Yunyun Li, Optimal sizing of utility-scale photovoltaic power generation complementarily operating with hydropower: A case study of the world's largest hydro-photovoltaic plant, *Energy Conversion and Management*, vol. 136, pp. 161-172, 15 March 2017
- [16] F.R. Pazheri, 'Tri-generation based hybrid power plant scheduling for renewable resources rich area with energy storage', *Energy Conversion and Management*, vol. 103, pp. 717-725, October 2015
- [17] Xinjing Zhang, Haiheng Chen, Yujie Xu, Wen Li, Fengjuan He, Huan Guo, Ye Huang, Design and Performance Analysis of the Distributed Generation System Based on a Diesel Engine and Compressed Air Energy Storage, *Energy Procedia*, vol. 105, pp. 4492-4498, May 2017
- [18] Somayeh Ahmadi, Mohammad Rezaei Mirghaed, Ramin Roshandel, Performance of a stand-alone wind-hydrogen power system for regions with seasonal wind profile: A case study in Khaf region, *Sustainable Energy Technologies and Assessments*, vol. 7, pp. 265-278, September 2014
- [19] Damian Gaiouris, Athanasios I.Papadopoulos, Chrysovalantou Zigoou, Dimitris Ipsakis, Spyros Voutetakis, Simira Papadopoulou, Panos Seferlis, Fotis Stergiopoulos, Costas Elmasides, Performance investigation of a hybrid renewable power generation and storage system using systemic power management models, *Energy*, vol. 61, pp. 621-635, 1 November 2013
- [20] Zahnd Alex, Angel Clark, Wendy Cheung, Linda Zou, Jan Kleissl Prof, Minimizing the Lead-Acid Battery Bank Capacity through a Solar PV - Wind Turbine Hybrid System for a high-altitude village in the Nepal Himalayas, *Energy Procedia*, vol. 57, pp. 1516-1525, 2014
- [21] József Paska, Piotr Biczek, Mariusz Klos, Hybrid power systems – An effective way of utilising primary energy sources, *Renewable Energy*, vol. 34, Issue 11, pp. 2414-2421, November 2009
- [22] Firdaus Basrawi, Takanobu Yamada, Shin'ya Obara, Economic and environmental based operation strategies of a hybrid photovoltaic-microgas turbine trigeneration system, *Applied Energy*, vol. 121, pp. 174-183, 15 May 2014
- [23] U.Sahoo, R.Kumar, P.C.Pant, R.Chaudhury, Scope and sustainability of hybrid solar-biomass power plant with cooling, desalination in polygeneration process in India, *Renewable and Sustainable Energy Reviews*, vol. 51, pp. 304-316, November 2015
- [24] Mauricio Bustamante, Wei Liao, 'A self-sustaining high-strength wastewater treatment system using solar-bio-hybrid power generation', *Bioresource Technology*, vol. 234, pp. 415-423, June 2017
- [25] Esmail M.A.Mokheimer, Ahmet Z.Sahin, Abdullah Al-Sharafi, Ahmad I.Ali, Modeling and optimization of hybrid wind-solar-powered reverse osmosis water desalination system in Saudi Arabia, *Energy Conversion and Management*, vol. 75, pp. 86-97, November 2013
- [26] Faruk Kose, Mehmet Numan Kaya, Analysis on meeting the electric energy demand of an active plant with a wind-hydro hybrid power station in Konya, Turkey: Konya water treatment plant, *Renewable Energy*, vol. 55, pp. 196-201, July 2013
- [27] Fahd Diab, Hai Lan, Salwa Ali, Novel comparison study between the hybrid renewable energy systems on land and on ship, *Renewable and Sustainable Energy Reviews*, vol. 63, pp. 452-463, September 2016
- [28] Boram Kim, Tae-wan Kim, Scheduling and cost estimation simulation for transport and installation of floating hybrid generator platform, *Renewable Energy*, vol. 111, pp. 131-146, October 2017
- [29] Tony El Tawil, Jean Frédéric Charpentier, Mohamed Benbouzid, Sizing and rough optimization of a hybrid renewable-based farm in a stand-alone marine context, *Renewable Energy*, vol. 115, pp. 1134-1143, January 2018
- [30] Hai Lan, Shuli Wen, Ying-Yi Hong, David C.Yu, Lijun Zhang, Optimal sizing of hybrid PV/diesel/battery in ship power system, *Applied Energy*, vol. 158, pp. 26-34, 15 November 2015
- [31] Shuli Wen, Hai Lan, Ying-Yi Hong, David C.Yu, Lijun Zhang, Peng Cheng, Allocation of ESS by interval optimization method considering impact of ship swinging on hybrid PV/diesel ship power system, *Applied Energy*, vol. 175, pp. 158-167, 1 August 2016
- [32] Hongbo Ren, Qiong Wu, Weijun Gao, Weisheng Zhou, Optimal operation of a grid-connected hybrid PV/fuel cell/battery energy system for residential applications, *Energy*, vol. 113, pp. 702-712, 15 October 2016
- [33] Wei Wu, Veni Indah Christiana, Scenario-oriented Design of a Stand-alone Hybrid Power Generation System Using Ammonia/Urine, *Energy Procedia*, vol. 61, pp. 1707-1712, 2014
- [34] Asma Chadel, Meriem Chadel, Michel Aillerie, Boumediene Benyoucef, Technical and economic analysis of hybrid solar/wind energy source for the site of Tlemcen-Algeria, *Energy Procedia*, vol. 119, pp. 29-37, July 2017
- [35] Wei Wu, Shin-An Chen, Jenn-Jiang Hwang, Fu-Teng Hsu, Optimization and control of a stand-alone hybrid solid oxide fuel cells/gas turbine system coupled with dry reforming of methane, *Journal of Process Control*, vol. 54, pp. 90-100, June 2017
- [36] Santanu Pramanik, R.V.Ravikrishna, A review of concentrated solar power hybrid technologies, *Applied Thermal Engineering*, vol. 127, pp. 602-637, 25 December 2017
- [37] Alan Emanuel Duailibe Ribeiro, Mauricio Cardoso Arouca, Daniel Moreira Coelho, Electric energy generation from small-scale solar and wind power in Brazil: The influence of location, area and shape, *Renewable Energy*, vol. 85, pp. 554-563, January 2016
- [38] Heetae Kim, Seoin Baek, Eunil Park, Hyun Joon Chang, Optimal green energy management in Jeju, South Korea – On-grid and off-grid electrification, *Renewable Energy*, vol. 69, pp. 123-133, September 2014
- [39] Subhadeep Bhattacharjee, Anindita Dey, Techno-economic performance evaluation of grid integrated PV-biomass hybrid power generation for rice mill, *Sustainable Energy Technologies and Assessments*, vol. 7, pp. 6-16, September 2014
- [40] G.D. Anbarasi Jebaselvi, S.Paramasivam, Analysis on renewable energy systems, *Renewable and Sustainable Energy Reviews*, vol. 28, pp. 625-634, December 2013
- [41] Wei Zhou, Hongxing Yang, Zhaohong Fang, Battery behavior prediction and battery working states analysis of a hybrid solar-wind power generation system, *Renewable Energy*, vol. 33, Issue 6, pp. 1413-1423, June 2008
- [42] Jinsheng Xiao, Xuehua Guan, Performance Analysis of Hybrid Solar-Hydrogen Energy System, *Physics Procedia*, vol. 24, Part A, pp. 735-742, 2012
- [43] Xuemin Ye, Jia Wang, Chunxi Li, Performance and emission reduction potential of renewable energy aided coal-fired power generation systems, *Energy*, vol. 113, pp. 966-979, 15 October 2016
- [44] H.R.Fallah Kohan, F.Lotfipour, M.Eslami, Numerical simulation of a photovoltaic thermoelectric hybrid power generation system, *Solar Energy*, vol. 174, pp. 537-548, 1 November 2018
- [45] Wei Zhu, Yuan Deng, Yao Wang, Shengfei Shen, Raza Gulfam, High-performance photovoltaic-thermoelectric hybrid power generation system with optimized thermal management, *Energy*, vol. 100, pp. 91-101, 1 April 2016
- [46] M.K.Deshmukh, S.S.Deshmukh, Modeling of hybrid renewable energy systems, *Renewable and Sustainable Energy Reviews*, vol. 12, Issue 1, pp. 235-249, January 2008
- [47] Hassan Zahboune, Smail Zouggar, Goran Krajacic, Petar Sabej Varbanov, Mohammed Elhafyani, Elmostafa Ziani, Optimal hybrid renewable energy design in autonomous system using Modi-

- fied Electric System Cascade Analysis and HOMER software, Energy Conversion and Management, vol. 126, pp. 909-922, 15 October 2016
- [48] Sharifah Rafidah Wan Alwi, Nor Erniza Mohammad Rozali, Zainuddin Abdul-Manan, Jifri Jaromir Klemes, A process integration targeting method for hybrid power systems, Energy, vol. 44, Issue 1, pp. 6-10, August 2012
- [49] Pragya Nema, R.K.Nema, Saroj Rangnekar, A current and future state of art development of hybrid energy system using wind and PV-solar: A review, Renewable and Sustainable Energy Reviews, vol. 13, Issue 8, pp. 2096-2103, October 2009
- [50] Vahid Behraves, Asghar Akbari, Foroud Reza Keypour, Optimal sizing methodology for photovoltaic and wind hybrid rooftop generation systems in residential low voltage distribution networks, Solar Energy, vol. 173, pp. 17-33, October 2018
- [51] Hassan Fathabadi, Fuel cell/back-up battery hybrid energy conversion systems: Dynamic modeling and harmonic considerations, Energy Conversion and Management, vol. 103, pp. 573-584, October 2015
- [52] Wei Wu, Ya-Yan Zhou, Mu-Hsuan Lin, Jenn-Jiang Hwang, Modeling, design and analysis of a stand-alone hybrid power generation system using solar/urine, Energy Conversion and Management, vol. 74, pp. 344-352, October 2013
- [53] Yuanyuan Li, Na Zhang, Ruixian Cai, Yongping Yang, Performance analysis of a near zero CO<sub>2</sub> emission solar hybrid power generation system, Applied Energy, vol. 112, pp. 727-736, December 2013
- [54] Zeting Yu, Jitian Han, Xianqi Cao, Wei Chen, Bin Zhang, Analysis of total energy system based on solid oxide fuel cell for combined cooling and power applications, International Journal of Hydrogen Energy, vol. 35, Issue 7, pp. 2703-2707, April 2010
- [55] Sajjad Mahmoudinezhad, Shaowei Qing, Alireza Rezaianikolaei, Lasse Aistrup Rosendahl, Transient Model of Hybrid Concentrated Photovoltaic with Thermoelectric Generator, Energy Procedia, vol. 142, pp. 564-569, December 2017
- [56] R.Nazir, H.D.Laksono, E.P.Waldi, E.Ekaputra, P.Coveria, Renewable Energy Sources Optimization: A Micro-Grid Model Design, Energy Procedia, vol. 52, pp. 316-327, 2014
- [57] Barun K.Das, Najmul Hoque, Soumya Mandal, Tapas Kumar Pal, Md Abu Raihan, A techno-economic feasibility of a stand-alone hybrid power generation for remote area application in Bangladesh, Energy, vol. 134, pp. 775-788, 1 September 2017
- [58] Alireza Haghighat Mamaghani, Sebastian Alberto Avella Escandon, Behzad Najafi, Ali Shirazi, Fabio Rinaldi, Techno-economic feasibility of photovoltaic, wind, diesel and hybrid electrification systems for off-grid rural electrification in Colombia, Renewable Energy, vol. 97, pp. 293-305, November 2016
- [59] B.O.Ariyo, M.F.Akorede, I.O.A.Omeiza, S.A.Y.Amuda, S.A.Oladeji, Optimisation analysis of a stand-alone hybrid energy system for the senate building, university of Ilorin, Nigeria, Journal of Building Engineering, vol. 19, pp. 285-294, September 2018
- [60] Cihan Gokool, Bahtiyar Dursun, A comprehensive economical and environmental analysis of the renewable power generating systems for Kırklareli University, Turkey, Energy and Buildings, vol. 64, pp. 249-257, September 2013
- [61] Bentouba Said, Hamouda Messaoud, Slimani Aek, Pere Roca iCabarcas, Bourouis Mahmoud, Coronas Alberto, Draoui Belkacem, Boucherit Med Seghir, Hybrid System and Environmental Evaluation Case House in South of Algeria, Energy Procedia, vol. 36, pp. 1328-1338, 2013
- [62] Getachew Bekele, Gelma Boneya, Design of a Photovoltaic-Wind Hybrid Power Generation System for Ethiopian Remote Area, Energy Procedia, vol. 14, pp. 1760-1765, 2012
- [63] Mehdi Baneshi, Farhad Hadianfard, Techno-economic feasibility of hybrid diesel/PV/wind/battery electricity generation systems for non-residential large electricity consumers under southern Iran climate conditions, Energy Conversion and Management, vol. 127, pp. 233-244, 1 November 2016
- [64] Mehdi Mehrpooya, Mohammad Mohammadi, Esmail Ahmadi, Techno-economic-environmental study of hybrid power supply system: A case study in Iran, Sustainable Energy Technologies and Assessments, vol. 25, pp. 1-10, February 2018
- [65] Sara Ghaem Sigarchian, Rita Paleta, Anders Malmquist, André Pina, Feasibility study of using a biogas engine as backup in a decentralized hybrid (PV/wind/battery) power generation system-Case study Kenya, Energy, vol. 90, Part 2, pp. 1830-1841, October 2015
- [66] Mojtaba Haratian, Pouya Tabibi, Meisam Sadeghi, Babak Vaseghi, Amin Poustdouz, A renewable energy solution for stand-alone power generation: A case study of KhshU Site-Iran, Renewable Energy, vol. 125, pp. 926-935, September 2018
- [67] Farivar Fazelpour, Nima Soltani, Marc A.Rosen, Feasibility of satisfying electrical energy needs with hybrid systems for a medium-size hotel on Kish Island, Iran, Energy, vol. 73, pp. 856-865, 14 August 2014
- [68] Mohammad Junaid Khan, Amit Kumar Yadav, Lini Mathew, Techno economic feasibility analysis of different combinations of PV-Wind-Diesel-Battery hybrid system for telecommunication applications in different cities of Punjab, India, Renewable and Sustainable Energy Reviews, vol. 76, pp. 577-607, September 2017
- [69] Normazlina Mat Isa, Himadry Shekhar Das, Chee Wei Tan, A.H.M.Yatim, Kwan Yiew Lau, A techno-economic assessment of a combined heat and power photovoltaic/fuel cell/battery energy system in Malaysia hospital, Energy, vol. 112, pp. 75-90, 1 October 2016
- [70] Himadry Shekhar Das, Chee Wei Tan, A.H.M.Yatim, Kwan Yiew Lau, Feasibility analysis of hybrid photovoltaic/battery/fuel cell energy system for an indigenous residence in East Malaysia, Renewable and Sustainable Energy Reviews, vol. 76, pp. 1332-1347, September 2017
- [71] S.M.Shaahid, M.A.Elhadidy, Economic analysis of hybrid photovoltaic-diesel-battery power systems for residential loads in hot regions-A step to clean future, Renewable and Sustainable Energy Reviews, vol. 12, Issue 2, pp. 488-503, February 2008
- [72] Prashant Kumar, Rahaul Pukale, Nilesh Kumabhar, Utkarsh Patil, Optimal Design Configuration Using HOMER, Procedia Technology, vol. 24, pp. 499-504, 2016
- [73] Jameel Ahmad, Muhammad Imran, Abdullah Khalid, Waseem Iqbal, Syed Rehan Ashraf, Muhammad Adnan, Syed Farooq Ali, Khawar Siddique Khokhar, Techno economic analysis of a wind-photovoltaic-biomass hybrid renewable energy system for rural electrification: A case study of Kallar Kahar, Energy, vol. 148, pp.208-234, 1 April 2018
- [74] Murat Gökçek, Integration of hybrid power (wind-photovoltaic-diesel-battery) and seawater reverse osmosis systems for small-scale desalination applications, Desalination, vol. 435, pp. 210-220, 1 June 2018
- [75] Sunanda Sinha, S.S.Chandel, Analysis of fixed tilt and sun tracking photovoltaic-micro wind based hybrid power systems, Energy Conversion and Management, vol. 115, pp. 265-275, 1 May 2016
- [76] Himadry Shekhar Das, A.H.M. Yatim, Chee Wei Tan, Kwan Yiew Lau, 'Proposition of a PV/tidal powered micro-hydro and diesel hybrid system: A southern Bangladesh focus', Renewable and Sustainable Energy Reviews, vol. 53, pp. 1137-1148, January 2016
- [77] Mohammad Hossein Amrollahi, Seyyed Mohammad Taghi Bathaee, Techno-economic optimization of hybrid photovoltaic/wind generation together with energy storage system in a stand-alone micro-grid subjected to demand response, Applied Energy, vol. 202, pp. 66-77, 15 September 2017
- [78] Marcelo Menezes Morato, Paulo Renatoda Costa Mendes, Alex Amadeu Cani, Julio Elias Normey-Rico, Carlos Bordons, Future Hybrid Local Energy Generation Paradigm for the Brazilian Sugarcane Industry Scenario, International Journal of Electrical Power & Energy Systems, vol. 101, pp. 139-150, October 2018
- [79] Lanre Olatomiwa, Saad Mekhilef, A.S.N.Huda, Olayinka S.Ohunakin, Economic evaluation of hybrid energy systems for rural electrification in six geo-political zones of Nigeria, Renewable Energy, vol. 83, pp. 435-446, November 2015
- [80] Sasmita Behera, Shobhit Nandkeolyar, Analysis of isolated hybrid system for power supply to a remote island, Energy Procedia, vol. 117, pp. 1040-1046, June 2011
- [81] Avisha Tah, Debapriya Das, Operation of small hybrid autonomous power generation system in isolated, interconnected and grid connected modes, Sustainable Energy Technologies and Assessments, vol. 17, pp. 11-25, October 2016
- [82] David Hernández-Torres, Olivier Sename, Delphine Riu, Florence Druart, On the Robust Control of DC-DC Converters: Application to a Hybrid Power Generation System, IFAC Proceedings Volumes, vol. 43, Issue 21, pp. 123-130, 2010
- [83] Dipayan Guha, Provas Kumar Roy, Subrate Banerjee, Optimal tuning of 3 degree-of-freedom proportional-integral-derivative controller for hybrid distributed power system using dragonfly algorithm, Computers & Electrical Engineering, vol. 72, pp. 137-153, November 2018
- [84] Giacomo Bruni, Stefano Cordiner, Matteo Galeotti, Vincenzo Mulone, Matteo Nobile, Vittorio Rocco, Control Strategy Influence

- on the Efficiency of a Hybrid Photovoltaic-Battery-Fuel Cell System Distributed Generation System for Domestic Applications, *Energy Procedia*, vol. 45, pp. 237-246, 2014
- [85] Yuehong Lu, Shengwei Wang, Kui Shan, Design optimization and optimal control of grid-connected and standalone nearly/net zero energy buildings, *Applied Energy*, vol. 155, pp. 463-477, 1 October 2015
- [86] Jean-Yves Dieulot, Frédéric Colas, Lamine Chalal, Geneviève Dauphin-Tanguy, Economic supervisory predictive control of a hybrid power generation plant, *Electric Power Systems Research*, vol. 127, pp. 221-229, October 2015
- [87] Chao Peng, Jianxiao Zou, Zhenzhen Zhang, Lu Han, Miao Liu, An Ultra-Short-Term Pre-Plan Power Curve based Smoothing Control Approach for Grid-connected Wind-Solar-Battery Hybrid Power System, *IFAC Papers On-Line*, vol. 50, Issue 1, pp. 7711-7716, July 2017
- [88] Ahmed M.Kassem, Ali M.Yousef, Voltage and frequency control of an autonomous hybrid generation system based on linear model predictive control, *Sustainable Energy Technologies and Assessments*, vol. 4, pp. 52-61, December 2013
- [89] P.Veena, V.Indragandhi, R.Jeyabharath, V.Subramaniaswamy, Review of grid integration schemes for renewable power generation system, *Renewable and Sustainable Energy Reviews*, vol. 34, pp. 628-641, June 2014
- [90] S.G.Malla, C.N.Bhende, Voltage control of stand-alone wind and solar energy system, *International Journal of Electrical Power & Energy Systems*, vol. 56, pp. 361-373, March 2014
- [91] J.I.Talpone, P.F.Puleston, J.J.More, R.Griño, M.G.Cendoya, Experimental platform for development and Evaluation of hybrid generation systems based on fuel cells, *International Journal of Hydrogen Energy*, vol. 37, Issue 13, pp. 10346-10353, July 2012
- [92] Hassan Fathabadi, Novel highly accurate universal maximum power point tracker for maximum power extraction from hybrid fuel cell/photovoltaic/wind power generation systems, *Energy*, vol. 116, Part 1, pp. 402-416, 1 December 2016
- [93] Hassan Fathabadi, Novel fast and high accuracy maximum power point tracking method for hybrid photovoltaic/fuel cell energy conversion systems, *Renewable Energy*, vol. 106, pp. 232-242, June 2017
- [94] Hassan Fathabadi, Novel high-efficient unified maximum power point tracking controller for hybrid fuel cell/wind systems, *Applied Energy*, vol. 183, pp. 1498-1510, 1 December 2016
- [95] W.Wu, J.P.Xu, J.J.Hwang, Multi-loop nonlinear predictive control scheme for a simplistic hybrid energy system, *International Journal of Hydrogen Energy*, vol. 34, Issue 9, pp. 3953-3964, May 2009
- [96] Adikanda Parida, Debashis Chatterjee, An improved control scheme for grid connected doubly fed induction generator considering wind-solar hybrid system, *International Journal of Electrical Power & Energy Systems*, vol. 77, pp. 112-122, May 2016
- [97] Su-Hyung Yang, Ho-Chan Kim, Chang-Jin Boo, Young Il Lee, Jae Sik Lim, Hee-Sang Ko, Kwang Y.Lee, Power Quality Control of Hybrid Wind Power Systems Using Robust Tracking Controller, *IFAC Proceedings Volumes*, vol. 45, Issue 21, pp. 729-734, 2012
- [98] Franco F.Yanine, Enzo E.Sauma, Review of grid-tie micro-generation systems without energy storage: Towards a new approach to sustainable hybrid energy systems linked to energy efficiency, *Renewable and Sustainable Energy Reviews*, vol. 26, pp. 60-95, October 2013
- [99] Zhou Wu, Henerica Tazvinga, Xiaohua Xia, Demand side management of photovoltaic-battery hybrid system, *Applied Energy*, vol. 148, pp. 294-304, 15 June 2015
- [100] Zehra Ural Bayrak, Gökay Bayrak, Mahmut Temel Ozdemir, Muhsin Tunay Gencoglu, Mehmet Cebeci, A low-cost power management system design for residential hydrogen & solar energy-based power plants, *International Journal of Hydrogen Energy*, vol. 41, Issue 29, pp. 12569-12581, 3 August 2016
- [101] Mario Petrollese, Daniele Cocco, Optimal design of a hybrid CSP-PV plant for achieving the full dispatchability of solar energy power plants, *Solar Energy*, vol. 137, pp. 477-489, 1 November 2016
- [102] Ali Habibollahzade, Ehsan Houshfar, Mehdi Ashjaee, Amirmohammad Behzadi, Ehsan Gholamian, Hamid Mehdizadeh, Enhanced power generation through integrated renewable energy plants: Solar chimney and waste-to-energy, *Energy Conversion and Management*, vol. 166, pp. 48-63, 15 June 2018
- [103] M.S.Jamel, A.Abd Rahman, A.H.Shamsuddin, Advances in the integration of solar thermal energy with conventional and non-conventional power plants, *Renewable and Sustainable Energy Reviews*, vol. 20, pp. 71-81, April 2013
- [104] Wenjia Li, Yong Hao, Explore the performance limit of a solar PV-thermochemical power generation system, *Applied Energy*, vol. 206, pp. 843-850, 15 November 2017
- [105] Zhang Bai, Qibin Liu, Jing Lei, Hui Hong, Hongguang Jin, New solar-biomass power generation system integrated a two-stage gasifier, *Applied Energy*, vol. 194, pp. 310-319, 15 May 2017
- [106] C.M. Iftekhar Hussain, Brian Norton, Aidan Duffy, Technological assessment of different solar-biomass systems for hybrid power generation in Europe, *Renewable and Sustainable Energy Reviews*, vol. 68, Part 2, pp. 1115-1129, February 2017
- [107] Zhang Bai, Qibin Liu, Jing Lei, Xiaohe Wang, Jie Sun, Hongguang Jin, Thermodynamic evaluation of a novel solar-biomass hybrid power generation system, *Energy Conversion and Management*, vol. 142, pp. 296-306, 15 June 2017
- [108] Mohammad Saghafifar, Mohamed Gadalla, Thermo-economic optimization of hybrid solar Maisotsenko bottoming cycles using heliostat field collector: Comparative analysis, *Applied Energy*, vol. 190, pp. 686-702, 15 March 2017
- [109] Tianjun Liao, Bihong Lin, Zhimin Yang, Performance characteristics of a low concentrated photovoltaic-thermoelectric hybrid power generation device, *International Journal of Thermal Sciences*, vol. 77, pp. 158-164, March 2014
- [110] Ravita Lamba, S.C.Kaushik, Modeling and performance analysis of a concentrated photovoltaic-thermoelectric hybrid power generation system, *Energy Conversion and Management*, vol. 115, pp. 288-298, 1 May 2016
- [111] Jian Lin, Tianjun Liao, Bihong Lin, Performance analysis and load matching of a photovoltaic-thermoelectric hybrid system, *Energy Conversion and Management*, vol. 105, pp. 891-899, 15 November 2015
- [112] Guiqiang Li, Samson Shittu, Thierno M.O.Diallo, Min Yu, Xudong Zhao, Jie Ji, A review of solar photovoltaic-thermoelectric hybrid system for electricity generation, *Energy*, vol. 158, pp. 41-58, 1 September 2018
- [113] Alibakhsh Kasaeian, Giti Nouri, Parisa Ranjbaran, Dongsheng Wen, Solar collectors and photovoltaics as combined heat and power systems: A critical review, *Energy Conversion and Management*, vol. 156, pp.688-705, 15 January 2018
- [114] Qibin Liu, Zhang Bai, Xiaohe Wang, Jing Lei, Hongguang Jin, Investigation of thermodynamic performances for two solar-biomass hybrid combined cycle power generation systems, *Energy Conversion and Management*, vol. 122, pp. 252-262, 15 August 2016
- [115] Ting Yue, Noam Lior, Thermal hybrid power systems using multiple heat sources of different temperature: Thermodynamic analysis for Brayton cycles, *Energy*, vol. 165, Part A, pp. 639-665, 15 December 2018
- [116] Amir Hossein Fakehi, Somayeh Ahmadi, Mohammad Rezaie Mirghaed, Optimization of operating parameters in a hybrid wind-hydrogen system using energy and exergy analysis: Modeling and case study, *Energy Conversion and Management*, vol. 106, pp. 1318-1326, December 2015
- [117] Wangying Shi, Minfang Han, A conceptual design of catalytic gasification fuel cell hybrid power plant with oxygen transfer membrane, *Journal of Power Sources*, vol. 361, pp. 211-220, 1 September 2017
- [118] Young Duk Lee, Kook Young Ahn, Tatiana Morosuk, George Tsatsaroni, Exergetic and exergoeconomic evaluation of an SOFC-Engine hybrid power generation system, *Energy*, vol. 145, pp. 810-822, 15 February 2018

- [119] Annamaria Buonomano, Francesco Calise, Massimo Dentice d'Accadia, Adolfo Palombo, Maria Vicidomini, Hybrid solid oxide fuel cells–gas turbine systems for combined heat and power: A review, *Applied Energy*, vol. 156, pp. 32-85, 15 October 2015
- [120] Jamasb Pirkandi, Mostafa Mahmoodi Mohammad Ommian, An optimal configuration for a solid oxide fuel cell-gas turbine (SOFC-GT) hybrid system based on thermo-economic modelling, *Journal of Cleaner Production*, vol. 144, pp. 375-386, 15 February 2017
- [121] Y.Komatsu, S.Kimijima, J.S.Szmyd, Performance analysis for the part-load operation of a solid oxide fuel cell–micro gas turbine hybrid system, *Energy*, vol. 35, Issue 2, pp. 982-988, February 2010
- [122] Po-Chih Kuo, Wei Wu, Design and thermodynamic analysis of a hybrid power plant using torrefied biomass and coal blends, *Energy Conversion and Management*, vol. 111, pp. 15-26, 1 March 2016
- [123] Qiang Liu, Linlin Shang, Yuanyuan Duan, Performance analyses of a hybrid geothermal–fossil power generation system using low-enthalpy geothermal resources, *Applied Energy*, vol.162, pp. 149-162, 15 January 2016
- [124] Pengcheng Li, Jing Li, Gang Pei, Anjum Munir, Jie Ji, A cascade organic Rankine cycle power generation system using hybrid solar energy and liquefied natural gas, *Solar Energy*, vol. 127, pp. 136-146, April 2016
- [125] Yasuto Tanaka, Sennai Mesfun, Kentaro Umeki, Andrea Toffolo, Yutaka Tamaura, Kunio Yoshikawa, Thermodynamic performance of a hybrid power generation system using biomass gasification and concentrated solar thermal processes, *Applied Energy*, vol. 160, pp. 664-672, 15 December 2015
- [126] Yasuto Tanaka, Kentaro Umeki, Yutaka Tamaura, Kunio Yoshikawa, Performance of a Hybrid Power Generation System Using Biomass Gasification and Concentrated Solar Thermal Processes, *Energy Procedia*, vol. 61, pp. 2149-2153, 2014
- [127] R.Bet Sarkis, V.Zare, Proposal and analysis of two novel integrated configurations for hybrid solar-biomass power generation systems: Thermodynamic and economic evaluation, *Energy Conversion and Management*, vol. 160, pp. 411-425, 15 March 2018

ORIGINALITY REPORT

% **15**  
SIMILARITY INDEX

% **9**  
INTERNET SOURCES

% **14**  
PUBLICATIONS

% **2**  
STUDENT PAPERS

PRIMARY SOURCES

**1** [worldwidescience.org](http://worldwidescience.org) % **1**  
Internet Source

**2** [journals.univ-danubius.ro](http://journals.univ-danubius.ro) % **1**  
Internet Source

**3** [mafiadoc.com](http://mafiadoc.com) % **1**  
Internet Source

**4** [eprints.utm.my](http://eprints.utm.my) <% **1**  
Internet Source

**5** [www.mdpi.com](http://www.mdpi.com) <% **1**  
Internet Source

**6** Ye, Xuemin, Jia Wang, and Chunxi Li. <% **1**  
"Performance and emission reduction potential  
of renewable energy aided coal-fired power  
generation systems", Energy, 2016.  
Publication

**7** [www.tandfonline.com](http://www.tandfonline.com) <% **1**  
Internet Source

**8** [s3.amazonaws.com](http://s3.amazonaws.com) <% **1**  
Internet Source

9

Jianfeng Dai, Yi Tang, Yan Xu, Quanchun Yan. "Reactive Power Optimization Coordinated Control Strategy of the Large-Scale PV Power Station", 2018 International Conference on Power System Technology (POWERCON), 2018

Publication

<% 1

10

[repository.unhas.ac.id](https://repository.unhas.ac.id)

Internet Source

<% 1

11

[article.ijsgge.net](https://article.ijsgge.net)

Internet Source

<% 1

12

Hassan Fathabadi. "Fuel cell/back-up battery hybrid energy conversion systems: Dynamic modeling and harmonic considerations", Energy Conversion and Management, 2015

Publication

<% 1

13

Sina Makhdoomi, Alireza Askarzadeh. "Daily performance optimization of a grid-connected hybrid system composed of photovoltaic and pumped hydro storage (PV/PHS)", Renewable Energy, 2020

Publication

<% 1

14

Dipayan Guha, Provas Kumar Roy, Subrate Banerjee. "Optimal tuning of 3 degree-of-freedom proportional-integral-derivative controller for hybrid distributed power system

<% 1

## using dragonfly algorithm", Computers & Electrical Engineering, 2018

Publication

---

15

Jijian Lian, Yusheng Zhang, Chao Ma, Yang Yang, Evance Chaima. "A review on recent sizing methodologies of hybrid renewable energy systems", Energy Conversion and Management, 2019

Publication

---

<% 1

16

Lu, Yuehong, Shengwei Wang, and Kui Shan. "Design optimization and optimal control of grid-connected and standalone nearly/net zero energy buildings", Applied Energy, 2015.

Publication

---

<% 1

17

Submitted to Universitas Diponegoro

Student Paper

---

<% 1

18

Murat Gökçek, Cihangir Kale. "Optimal design of a Hydrogen Refuelling Station (HRFS) powered by Hybrid Power System", Energy Conversion and Management, 2018

Publication

---

<% 1

19

J.I. Talpone, P.F. Puleston, J.J. More, R. Griño, M.G. Cendoya. "Experimental platform for development and Evaluation of hybrid generation systems based on fuel cells", International Journal of Hydrogen Energy, 2012

Publication

---

<% 1

- |    |  |      |
|----|--|------|
| 20 | <a href="http://res.mdpi.com">res.mdpi.com</a><br>Internet Source  | <% 1 |
| 21 | Nadjemi, O., T. Nacer, A. Hamidat, and H. Salhi. "Optimal hybrid PV/wind energy system sizing: Application of cuckoo search algorithm for Algerian dairy farms", Renewable and Sustainable Energy Reviews, 2016.<br>Publication          | <% 1 |
| 22 | <a href="http://www.ifac2017.org">www.ifac2017.org</a><br>Internet Source  | <% 1 |
| 23 | <a href="http://repositorio.uc.cl">repositorio.uc.cl</a><br>Internet Source  | <% 1 |
| 24 | <a href="http://kundoc.com">kundoc.com</a><br>Internet Source  | <% 1 |
| 25 | <a href="http://www.ipcbee.com">www.ipcbee.com</a><br>Internet Source  | <% 1 |
| 26 | Buonomano, Annamaria, Francesco Calise, Massimo Dentice d'Accadia, Adolfo Palombo, and Maria Vicidomini. "Hybrid solid oxide fuel cells–gas turbine systems for combined heat and power: A review", Applied Energy, 2015.<br>Publication | <% 1 |
| 27 | Vahid Behraves, Asghar Akbari Foroud, Reza Keypour. "Optimal sizing methodology for photovoltaic and wind hybrid rooftop generation  | <% 1 |

systems in residential low voltage distribution networks", Solar Energy, 2018

Publication

28

[eprints.kfupm.edu.sa](http://eprints.kfupm.edu.sa)

Internet Source

<% 1

29

Mojtaba Haratian, Pouya Tabibi, Meisam Sadeghi, Babak Vaseghi, Amin Poustdouz. "A Renewable Energy Solution for Stand-alone Power Generation: A Case Study of KhshU Site-Iran", Renewable Energy, 2018

Publication

<% 1

30

W.D. Kellogg, M.H. Nehrir, G. Venkataramanan, V. Gerez. "Generation unit sizing and cost analysis for stand-alone wind, photovoltaic, and hybrid wind/PV systems", IEEE Transactions on Energy Conversion, 1998

Publication

<% 1

31

Lamba, Ravita, and S.C. Kaushik. "Modeling and performance analysis of a concentrated photovoltaic–thermoelectric hybrid power generation system", Energy Conversion and Management, 2016.

Publication

<% 1

32

Submitted to Heriot-Watt University

Student Paper

<% 1

33

Alireza Haghighat Mamaghani, Sebastian Alberto Avella Escandon, Behzad Najafi, Ali

<% 1

Shirazi, Fabio Rinaldi. "Techno-economic feasibility of photovoltaic, wind, diesel and hybrid electrification systems for off-grid rural electrification in Colombia", Renewable Energy, 2016

Publication

---

34

Hassan Fathabadi. "Novel highly accurate universal maximum power point tracker for maximum power extraction from hybrid fuel cell/photovoltaic/wind power generation systems", Energy, 2016

Publication

---

35

Das, Himadry Shekhar, A.H.M. Yatim, Chee Wei Tan, and Kwan Yiew Lau. "Proposition of a PV/tidal powered micro-hydro and diesel hybrid system: A southern Bangladesh focus", Renewable and Sustainable Energy Reviews, 2016.

Publication

---

36

Submitted to Universiti Teknologi Malaysia

Student Paper

---

37

[escholarship.org](http://escholarship.org)

Internet Source

---

38

[www.semanticscholar.org](http://www.semanticscholar.org)

Internet Source

---

39

Hassan Al Garni, Anjali Awasthi. "Techno-

<% 1

<% 1

<% 1

<% 1

<% 1

<% 1

economic feasibility analysis of a solar PV grid-connected system with different tracking using HOMER software", 2017 IEEE International Conference on Smart Energy Grid Engineering (SEGE), 2017

Publication

40

[www.ijrer.org](http://www.ijrer.org)

Internet Source

<% 1

41

[lww.cn](http://lww.cn)

Internet Source

<% 1

42

Olubayo Moses Babatunde, Josiah Lange Munda, Yskandar Hamam. "A Comprehensive State-of-the-Art Survey on Hybrid Renewable Energy System Operations and Planning", IEEE Access, 2020

Publication

<% 1

43

Tomar, Vivek, and G.N. Tiwari. "Techno-economic evaluation of grid connected PV system for households with feed in tariff and time of day tariff regulation in New Delhi – A sustainable approach", Renewable and Sustainable Energy Reviews, 2016.

Publication

<% 1

44

Sajjad Mahmoudinezhad, Shaowei Qing, Alireza Rezaniakolaei, Lasse Aistrup Rosendahl. "Transient Model of Hybrid Concentrated Photovoltaic with Thermoelectric Generator",

<% 1

45 Boram Kim, Tae-wan Kim. "Scheduling and cost estimation simulation for transport and installation of floating hybrid generator platform", Renewable Energy, 2017 <% 1  
Publication

---

46 Marcelo Menezes Morato, Paulo Renato da Costa Mendes, Julio Elias Normey-Rico, Carlos Bordons. "LPV-Filtered Predictive Control Design for Fault-Tolerant Energy Management", IFAC-PapersOnLine, 2019 <% 1  
Publication

---

47 Khani, Leyla, Ali Saberi Mehr, Mortaza Yari, and S.M.S. Mahmoudi. "Multi-objective optimization of an indirectly integrated solid oxide fuel cell-gas turbine cogeneration system", International Journal of Hydrogen Energy, 2016. <% 1  
Publication

---

48 [ideas.repec.org](http://ideas.repec.org) <% 1  
Internet Source

---

49 [doi.org](http://doi.org) <% 1  
Internet Source

---

50 Ahmed M. Kassem, Ali M. Yousef. "Voltage and frequency control of an autonomous hybrid generation system based on linear model predictive control", Sustainable Energy <% 1

51

[upcommons.upc.edu](http://upcommons.upc.edu)

Internet Source

<% 1

---

52

Domenico Mazzeo, Cristina Baglivo, Nicoletta Matera, Paolo M. Congedo, Giuseppe Oliveti. "A novel energy-economic-environmental multi-criteria decision-making in the optimization of a hybrid renewable system", *Sustainable Cities and Society*, 2020

Publication

<% 1

---

53

Zhou, W.. "Current status of research on optimum sizing of stand-alone hybrid solar-wind power generation systems", *Applied Energy*, 201002

Publication

<% 1

---

54

Himadry Shekhar Das, Chee Wei Tan, A.H.M. Yatim, Kwan Yiew Lau. "Feasibility analysis of hybrid photovoltaic/battery/fuel cell energy system for an indigenous residence in East Malaysia", *Renewable and Sustainable Energy Reviews*, 2017

Publication

<% 1

---

55

Ajai Gupta, R. P. Saini, M. P. Sharma. "Steady-state modelling of Hybrid Energy System", 2009 Third International Conference on Electrical Engineering, 2009

<% 1

---

**56** Maleki, Akbar, Fathollah Pourfayaz, and Mohammad Hossein Ahmadi. "Design of a cost-effective wind/photovoltaic/hydrogen energy system for supplying a desalination unit by a heuristic approach", Solar Energy, 2016.

Publication

---

**57** "Abstracts", Fuel and Energy Abstracts, 2015.

Publication

---

**58** [aip.scitation.org](http://aip.scitation.org)

Internet Source

---

**59** Mir-Akbar Hessami, Hugh Campbell, Christopher Sanguinetti. "A feasibility study of hybrid wind power systems for remote communities", Energy Policy, 2011

Publication

---

**60** Zhang, Xiaofeng, Hongqiang Li, Lifang Liu, Rong Zeng, and Guoqiang Zhang. "Analysis of a feasible trigeneration system taking solar energy and biomass as co-feeds", Energy Conversion and Management, 2016.

Publication

---

**61** [eprints.whiterose.ac.uk](http://eprints.whiterose.ac.uk)

Internet Source

---

**62** Tianjun Liao, Bihong Lin, Zhimin Yang. "Performance characteristics of a low

concentrated photovoltaic–thermoelectric hybrid power generation device", International Journal of Thermal Sciences, 2014

Publication

---

63

"JFEA\_49\_2\_abstracts", Fuel and Energy Abstracts, 200803

Publication

---

64

Luca Cioccolanti, Roberto Tascioni, Alessia Arteconi. "Mathematical modelling of operation modes and performance evaluation of an innovative small-scale concentrated solar organic Rankine cycle plant", Applied Energy, 2018

Publication

---

65

[www.science.gov](http://www.science.gov)

Internet Source

---

66

Chrysovalantou Ziogou, Efstratios N. Pistikopoulos, Michael C. Georgiadis, Spyros Voutetakis, Simira Papadopoulou. "Empowering the Performance of Advanced NMPC by Multiparametric Programming—An Application to a PEM Fuel Cell System", Industrial & Engineering Chemistry Research, 2013

Publication

---

67

Shaahid, S.M.. "Economic analysis of hybrid photovoltaic-diesel-battery power systems for residential loads in hot regions-A step to clean

<% 1

<% 1

<% 1

<% 1

<% 1

future", Renewable and Sustainable Energy  
Reviews, 200802

Publication

---

68

Javier Mendoza-Vizcaino, Muhammad Raza, Andreas Sumper, Francisco Díaz-González, Samuel Galceran-Arellano. "Integral approach to energy planning and electric grid assessment in a renewable energy technology integration for a 50/50 target applied to a small island", Applied Energy, 2019

Publication

---

69

K. Salman Khan, Z. Ullah, B. Khan, I. Sami, S. M. Ali, C. A. Mehmood. "Assessment of hybrid off-grid wind photovoltaic system: A case study of university campus", 2017 International Conference on Energy Conservation and Efficiency (ICECE), 2017

Publication

---

70

Majid Aasadnia, Mehdi Mehrpooya, Hojat Ansarinasab. "A 3E evaluation on the interaction between environmental impacts and costs in a hydrogen liquefier combined with absorption refrigeration systems", Applied Thermal Engineering, 2019

Publication

---

71

Submitted to Universiti Brunei Darussalam

Student Paper

---

<% 1

<% 1

<% 1

<% 1

72

Ghaem Sigarchian, Sara, Rita Paleta, Anders Malmquist, and André Pina. "Feasibility study of using a biogas engine as backup in a decentralized hybrid (PV/wind/battery) power generation system – Case study Kenya", Energy, 2015.

Publication

&lt;% 1

73

Jinsheng Xiao, Xuehua Guan. "Performance Analysis of Hybrid Solar-Hydrogen Energy System", Physics Procedia, 2012

Publication

&lt;% 1

74

[es.scribd.com](http://es.scribd.com)

Internet Source

&lt;% 1

75

Nema, P.. "A current and future state of art development of hybrid energy system using wind and PV-solar: A review", Renewable and Sustainable Energy Reviews, 200910

Publication

&lt;% 1

76

Simin Anvari, Shahram Khalilarya, Vahid Zare. "Power generation enhancement in a biomass-based combined cycle using solar energy: Thermodynamic and environmental analysis", Applied Thermal Engineering, 2019

Publication

&lt;% 1

77

[www.cogentoa.com](http://www.cogentoa.com)

Internet Source

&lt;% 1

78

Barun K. Das, Najmul Hoque, Soumya Mandal, Tapas Kumar Pal, Md Abu Raihan. "A techno-economic feasibility of a stand-alone hybrid power generation for remote area application in Bangladesh", Energy, 2017

Publication

&lt;% 1

79

Wu, Wei, Cheng-Yi Wang, and Jenn-Jiang Hwang. "Scenario-oriented design of an MFC/PV/Battery based hybrid power generation system", International Journal of Electrical Power & Energy Systems, 2015.

Publication

&lt;% 1

80

[www.sdewes.org](http://www.sdewes.org)

Internet Source

&lt;% 1

81

Erdinc, O.. "Recent trends in PEM fuel cell-powered hybrid systems: Investigation of application areas, design architectures and energy management approaches", Renewable and Sustainable Energy Reviews, 201012

Publication

&lt;% 1

82

W. Wu, J.P. Xu, J.J. Hwang. "Multi-loop nonlinear predictive control scheme for a simplistic hybrid energy system", International Journal of Hydrogen Energy, 2009

Publication

&lt;% 1

83

Nicu Bizon, Phatiphat Thounthong. "Energy Efficiency and Fuel Economy of a Fuel

&lt;% 1

# Cell/Renewable Energy Sources Hybrid Power System with the Load-Following Control of the Fueling Regulators", Mathematics, 2020

Publication

---

84

Samson Shittu, Guiqiang Li, Yousef Golizadeh Akhlaghi, Xiaoli Ma, Xudong Zhao, Emmanuel Ayodele. "Advancements in thermoelectric generators for enhanced hybrid photovoltaic system performance", Renewable and Sustainable Energy Reviews, 2019

Publication

---

85

Yu, Z.. "Analysis of total energy system based on solid oxide fuel cell for combined cooling and power applications", International Journal of Hydrogen Energy, 201004

Publication

---

86

Shuang-Ying Wu, Yi-Chen Zhang, Lan Xiao, Zu-Guo Shen. "Performance comparison investigation on solar photovoltaic-thermoelectric generation and solar photovoltaic-thermoelectric cooling hybrid systems under different conditions", International Journal of Sustainable Energy, 2017

Publication

---

87

Wei Wu, Veni Indah Christiana. "Scenario-oriented Design of a Stand-alone Hybrid Power

<% 1

<% 1

<% 1

<% 1

## Generation System Using Ammonia/Urine", Energy Procedia, 2014

Publication

---

88

Young Duk Lee, Kook Young Ahn, Tatiana Morosuk, George Tsatsaronis. "Exergetic and exergetic evaluation of an SOFC-Engine hybrid power generation system", Energy, 2018

Publication

---

<% 1

89

Muhammad Shahzad Aziz, Umair Saleem, Ehsan Ali, Khalid Siddiq. "A review on bi-source, off-grid hybrid power generation systems based on alternative energy sources", Journal of Renewable and Sustainable Energy, 2015

Publication

---

<% 1

90

Imane Worighi, Abdelilah Maach, Joeri Van Mierlo, Omar Hegazy. "Chapter 9 Towards a Realistic Design of Hybrid Micro-grid Systems Based on Double Auction Markets", Springer Science and Business Media LLC, 2019

Publication

---

<% 1

91

Soumya Mandal, Barun K. Das, Najmul Hoque. "Optimum Sizing of a Stand-alone Hybrid Energy System for Rural Electrification in Bangladesh", Journal of Cleaner Production, 2018

Publication

---

<% 1

92

Kavadias, K.A.. "Stand-Alone, Hybrid Systems",

93

Bin Wang, Dan Zhao, Weixuan Li, Zhiyu Wang, Yue Huang, Yancheng You, Sid Becker.

"Current technologies and challenges of applying fuel cell hybrid propulsion systems in unmanned aerial vehicles", Progress in Aerospace Sciences, 2020

Publication

<% 1

94

Zhou, W.. "Battery behavior prediction and battery working states analysis of a hybrid solar-wind power generation system", Renewable Energy, 200806

Publication

<% 1

95

Alan Emanuel Duailibe Ribeiro, Maurício Cardoso Arouca, Daniel Moreira Coelho.

"Electric energy generation from small-scale solar and wind power in Brazil: The influence of location, area and shape", Renewable Energy, 2016

Publication

<% 1

96

Ting Yue, Noam Lior. "Thermal hybrid power systems using multiple heat sources of different temperature: Thermodynamic analysis for Brayton cycles", Energy, 2018

Publication

<% 1

Sinha, Sunanda, and S.S. Chandel. "Review of

---

EXCLUDE QUOTES ON

EXCLUDE  
BIBLIOGRAPHY ON

EXCLUDE MATCHES < 5  
WORDS